

San Juan Pump Co.
61649 Gunnison Rd.
Montrose, Co 81401
970-275-2628

Well Test

Date: 7-1-2020 / 7-2-2020

Location: Specie Wilderness Ranch Placerville Co.

San Juan Pump Co. Performed 24 hour well test at above location

| | |
|------------------|---|
| well Permit # | 188704 |
| well Depth: | 310' |
| water level: | 129' |
| pumping level: | 290' |
| draw down to: | 204' |
| sustained yield: | 15 GPM |
| test pump: | submersible 4" 18 GPM 1.5 HP |
| power: | generator |
| recovery: | the water level recovered in one hour back to 129' |
| sample: | a water sample was taken at the end of 24 hour test and taken to the lab, |
| Comments: | the water was very rusty for the first hour and then cleared and remained clear for 24 hour test. A total of 21'600 gallons were pumped during the test. This well is a very good producing well. |

Contact: Jason with San Juan Pump Co. if you have any questions regarding the above data.

San Juan Pump
Jason Kastendieck Lic.# 1427